

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 2280-1585:100 Page 1 of 1

**CATEGORY:** Coating Materials

**LISTEE:** Tibbetts Newport Corp., 2335 S. Birch St., Santa Ana, CA 92707  
Contact: Shil K. Park (714) 546-6661 Fax (714) 546-5414

**DESIGN:** MODEL 34500 FIRE-LOC fire retardant water-based Acrylic Latex paint for interior use on ceiling tiles. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Flame spread: 10  
Smoke developed: 5  
Coverage Rate: 200 ft<sup>2</sup>/Gal.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product label and UL label.

**APPROVAL:** Listed as Class A coating material when used on ceiling tiles to reduce flame spread. Approval limited to interior ceiling surfaces when the coatings are applied at the rates specified above and in accordance with the manufacturer's installation instructions. Local Authority Having Jurisdiction should be consulted prior to installation.

02-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager